

# Pool Pump Room Daily Check List

Place check by each item, write in readings, status, or observation. Circle: Outdoor / Indoor

Attendant / Other: Walt Sobkiw

Date: 6/15/2018

## Operational Status

- Last Backwash Date and Water Color Unknown
- Flow Meter 1 Reading (bleed if needed) 0 no water present
- Flow Meter 2 Reading (bleed if needed) 0 no water present
- In-Fluent Pressure Tank A Reading 0 not connected
- Effluent Pressure Tank A Reading 0 not connected
- In-Fluent Pressure Tank B Reading unknown
- Effluent Pressure Tank B Reading unknown
- Electronic Units Status & Readings unknown
- Pump Strainer Water Level (air / no air) air present
- Pump Strainer Clear Of Leaves & Obstructions (yes / no) clear
- Pump Sound (normal / not normal) noisy – bad bearing
- Cavitation Sound (yes / no) yes cavitation sound

## Maintenance Condition

- Sand Install Date Tag Legible Date: unknown – no tag
- Pump Install Date Tag Legible Date: unknown – no tag
- Electronics Install Date Tag Legible Date: unknown – no tag
- Pump Room Instructions Present No
- Instructions Complete & Legible No instructions
- All Meters Labeled & Working No, No Labels
- All Valves Labeled & Working unknown, No Labels
- Power Panel Labeled & Working unknown, No Labels
- Electronic Panel Labeled & Working unknown, No Labels
- Chlorinator Labeled & Working unknown, No Labels

## Pool Pump Room Daily Check List

Place check by each item, write in readings, status, or observation. Circle:  Outdoor / Indoor

**Attendant / Other:** Walt Sobkiw

**Date:** 6/15/2018

### Comments

When the pump is turned off there are multiple water leaks including from the pump strainer clear top.

The pump room failed inspection. Corrective action is needed immediately, see check list and comments for specific actions.