



**Atlantic County Division of Public Health**  
**Environmental Health Unit**  
**201 South Shore Road**  
**Northfield, NJ 08225**  
**(606) 645-5971**

**Swimming Pool Inspection Report**

<b>Facility Name</b> Village at English Mill - Indoor Pool				<b>Owner Name</b> Tara Frontera - Associa Mid Atlantic, property manager			
<b>Facility Address</b> 1 Village Grande Road				<b>Mailing Address</b> 1 Village Grande RD			
<b>City</b> Egg Harbor Township	<b>State</b> NJ	<b>Zip Code</b> 08234	<b>Phone</b>	<b>City</b> Egg Harbor Twp	<b>State</b> NJ	<b>Zip Code</b> 08234	<b>Phone</b> (609)788-8405
<b>Name of Inspecting officer</b> Allen Benowitz			<b>Title</b> Senior R.E.H.S.		<b>REHS Lic Number</b> B-2033	<b>Name of Health Officer</b>	
<b>Record Number: Risk</b> PR0002786		<b>Municipality</b> 28 Egg Harbor Township		<b>Date</b> 03/17/2025	<b>Start</b> 10:00 AM	<b>Finish</b> 10:20 AM	
<b>Program Code:</b> 0202 Swimming Pools - Indoor		<b>Program Identifier</b> Village at English Mill - Indoor Pool		<b>Purpose of Inspection:</b> Swimming Pool Inspection		<b>Evaluation</b> Satisfactory	

Fill in the designated compliance status (IN OUT N/O, N/A) for each each numbered item Fill in the appropriate box for COS and/or R  
 IN = In compliance    OUT = Not in compliance    N/O = Not observed    N/A = Not applicable    COS = Corrected on-site during inspection    R = Repeat violation

<b>APPROVALS</b>		
1. Checklist submitted and approval issued		In
<b>PERSONNEL SUPERVISION</b>		
2. Lifeguards/Certification current/Attire and duties acceptable		N/A
3. Appropriate number of lifeguards provided		N/A
4. Designated Adult Supervisor		In
5. Trained Pool Operator certification current/documented visit once per week		In
<b>WATER QUALITY</b>		
6. Log book maintained		In
7. Complete test kit w/ readable comparator		In
8. Bromine level within acceptable range		In
9. Free chlorine level within acceptable range		N/A
10. Combined chlorine level within acceptable range		N/A
11. Ph within acceptable range		In
12. Water clarity acceptable		In
13. Water tested weekly by certified lab		In
<b>MAIN DRAIN(S)</b>		
14. Covers are intact & properly secured		In
15. Covers comply with VGB Act		In
16. 2 or more main drains at least 3 feet apart and connected to one pump		In
17. Single main drain is unblockable because length, width or diagonal is 36" or greater		N/A
18. Each single main drain has secondary backup system installed		N/A
<b>SAFETY FEATURES &amp; MAINTENANCE</b>		
19. Adequate lifeguard platforms / stands provided		N/A

20. Written aquatics facility plan	In
21. 1 or more assist poles or life hooks located in pool area/No telescoping pole or plastic hooks	In
22. 1 rescue tube per lifeguard or 1 ring buoy if facility is exempt	In
23. Complete first aid kit	In
24. Spine board with straps & head restraints at pool side	In
25. Phone or communicating device in working condition	In
26. Depth markings are on wall and deck, at least 4" , spaced no more than 25' intervals and no more than 2' increments of water depth	In
27. Fences & gates are in good repair	In
28. Locks provided at entrances	In
29. Skimmers are clean & free of excess debris	In
30. Pool deck area is clean & in good repair	In
31. Bathroom is clean, toilet tissue, soap & paper towels provided	In
32. Backwash is disposed of properly	In
33. Automated External Defibrillator (AED) for guarded pools and specially exempt health clubs	In
34. Throwline available long enough to reach other side of pool	In
<b>SIGNAGE (CONSPICUOUSLY POSTED)</b>	
35. Specially exempt facilities not complying with 8:26-5.2 shall prominently post a sign at least 3'x4' at every entrance stating: "No Lifeguard On Duty" , "Persons Under The Age of 16 Must Be Accompanied By An Adult", "No Swimming Alone"	In
36. At campgrounds, hotels, motels, mobile home parks, health clubs and retirement communities, the sign must also state: "This swimming area shall be closed when the owner or manager is not on the premises"	In
37. 8"x10" sign posted at front desk and in each guest room	In
38. Bathers rules posted (11 rules)	In
39. "No Diving" signs and symbols posted	In
40. "No Smoking" sign posted at chemical storage area	In
41. Emergency numbers posted in a weather resistant display adjacent to the telephone	In
42. Name & telephone # of designated adult supervisor is posted	In

**VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS**

<b>Item No</b>	<b>Remarks</b>
8	Bromine 6.0
11	Ph 7.4
34	Ring bout with rope

*Overall Inspection Comments:*

NJ State Recreational Bathing Code inspection revealed:

This is the first 2025 pool code inspection for this indoor pool.

2025 preposition checklist has been submitted to this office.

Frank Canale, Canale Pools, is TPO.



Frank Canale, TPO, was onsite for inspection. Frank Canale, Canale Pools, signed for the report emails to send inspection reports canalepools@gmail.com

Precision Analytical (York Labs) conducts weekly bacteria testing.

chemical readings

Bromine 6.0  
ph 7.4

Rating Satisfactory

<b>Received By:</b> Frank Canale		<b>Title:</b>	<b>Date:</b> 03/17/2025
<b>Inspector:</b> Allen Benowitz		<b>Title:</b> Senior R.E.H.S.	<b>Date:</b> 03/17/2025